



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-16682/M2

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: DEKRA Certification B.V.

Product: Moulded case circuit-breaker

Applicant: LSIS Co., Ltd. 1026-6, Hogye-dong, Korea, Republic of  
Dong-an-gu Anyang-si, Gyeonggi-do

Manufacturer: LSIS Co., Ltd. 1026-6, Hogye-dong, Korea, Republic of  
Dong-an-gu Anyang-si, Gyeonggi-do

Factory: LSIS Co., Ltd. CheongJu Plant 1, Songjeong-dong, Heungdeok-gu Cheongju-si, Chungcheongbuk-do Korea, Republic of

Rating and principal characteristics: 2, 3 and 4 pole thermal magnetic MCCB  
Ue = 220, 240, 250, 415, 440, 460 V  
Ie = 250, 300, 350, 400, 500, 630, 700, 800 A  
Ui = 750 Vac  
Uimp = 8 kV  
Ics = 75%Icu  
Rated frequency = 50/60 Hz  
Cat A. See also first pages of test reports

Trade mark (if any): LS

Type of Manufacturer's Testing Laboratories used: WMT

Model/Type reference: ABN/ABS/ABH/ABL402c, -403c, -404c, -802c, -803c, -804c, ABK803c

Additional information: Original issue date 2009-08-25.  
M1: Re-issued due to modifications for compliance of 80x models to Annex H and compliance of all MCCBs to suitable for isolation requirements.  
M2: Re-issued to add model ABK803c.

Sample of product tested to be in conformity with IEC: 60947-2(ed.4)

Test Report Ref. No: 2126589.50, -51, -52, -53, -54, -55

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

Signed by: F.S. Strikwerda

Date of issue: 2011-05-24



DEKRA Certification is former KEMA Quality