



IEC SYSTEM FOR CONFORMITY  
TESTING TO STANDARDS FOR  
SAFETY OF ELECTRICAL  
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-6475

## CB TEST CERTIFICATE

Issued by: KEMA Quality B.V.

Registration date: 2003-03-17

Product: Magnetic contactors, thermal overload relays, starters, contactor relay

Applicant: LG Industrial Systems Co., Ltd. Cheong Ju Plant, #1, Song Jung Dong, Hung Duk Ku, Cheong Ju, 361-720 Korea, Republic of

Manufacturer: LG Industrial Systems Co., Ltd. Cheong Ju Plant, #1, Song Jung Dong, Hung Duk Ku, Cheong Ju, 361-720 Korea, Republic of

Factory: LG Industrial Systems Co., Ltd. Cheong Ju Plant, #1, Song Jung Dong, Hung Duk Ku, Cheong Ju, 361-720 Korea, Republic of

Rating and principal characteristics: Main circuits: Ith 20 A, Ui 690 V, Uimp 6 kV, 220 V-690 V, 3-pole, AC1, AC2, AC3, AC4  
Aux. circuits: Ith 10 A, Ui 690 V, Uimp 6 kV, AC15, A600 120-600 V, DC13 Q300 120-250 V

Trade mark (if any): LGIS

Model/Type reference: Main circuits: GMC....., GMD....., GMS....., GTH....., GTK.... /  
Aux. circuits: GMR....., AU....., AR....., AZ....., GTH....., GTK.....

Additional information: -

Sample of product tested to be in conformity with IEC: 60947-4-1 (ed.1);am1;am2, 60947-5-1 (ed.2);am1;am2

Test Report Ref. No: Main circuits: 2022807.50 / -.53 and Aux. circuits: 2022807.54

This CB Test Certificate is issued by the National Certification Body

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

**KEMA**

Signed by: L.J.W. van Megen